Energy and Capacity Markets: Tradeoffs in Reliability, Costs, and Risks

Presented to Harvard Electricity Policy Group Seventy-Fourth Plenary Session

Prepared by Johannes P. Pfeifenberger Samuel A. Newell Kathleen Spees

February 27, 2014



Content

- I. When might we need a capacity market? (Or do we really?)
- II. Implications of ERCOT Report: Reliability, cost, and risk tradeoffs between energy-only and capacity markets
- III. Highlights from FERC Report: Impacts of interties, price caps, DR
- **IV.** Things to think about before implementing a capacity market
- V. Policy implications

Appendix A: Additional FERC Study Results Appendix B: Characteristics of Successful Capacity Markets (Additional Detail) Appendix C: Additional Reading, Author Contacts, About Brattle

This presentation is based on the following two reports:

- Newell, Spees, Pfeifenberger, Karkatsouli, Wintermantel, and Carden, *Estimating the Economically Optimal Reserve Margin in ERCOT*, Report prepared for The Public Utility Commission of Texas, The Brattle Group, January 31, 2014.
- Pfeifenberger, Spees, Carden, and Wintermantel, *Resource Adequacy Requirements: Reliability and Economic Implications*, Prepared for the Federal Energy Regulatory Commission (FERC), The Brattle Group, September 2013.

I. When Might We Need Capacity Markets?

Reserve-margin mandates (and the capacity market created by them) are generally called for when energy-only markets do not attract "adequate" investments:

- Energy market designs that lead to price suppression?
 - Low price caps and inadequate scarcity pricing?
 - Poor integration of demand-response resources?
 - Substantial locational differences not reflected in market prices?
 - Operational actions (e.g., dispatch of emergency resources) that depress clearing prices?
- Challenging investment risks (e.g., in hydro-dominated markets)?
- Distortions created by out-of-market payments for some resources that lead to over-supply or high costs?
- Incomplete or poorly-designed ancillary service markets?
 - Missing ramping products?
 - Not co-optimized with energy market?
 - Operational actions that depress clearing prices?
- Most Likely: Resource adequacy preferences (e.g., 1-in-10) higher than what even fully-efficient energy and A/S markets would provide 2 | brattle.com

II. Summary of Recent ERCOT Report

- The PUCT asked us to estimate the economically-optimal reserve margin in ERCOT to inform their ongoing review of market design for resource adequacy.
- Under base case assumptions, we estimate reserve margins of:
 - 10.2% economic optimum
 - 11.5% in equilibrium of current energy market design (minimizes customer cost)
 - 14.1% required to meet 1-in-10 reliability standard
- Enforcing a 1-in-10 reserve margin requirement at 14.1% (with or without a centralized capacity market) would increase long-run average customer costs by approximately 1% of retail rates relative to the 11.5% energy-only market in equilibrium :
 - Considered only energy and capacity price impacts
 - Potential additional benefits: risk mitigation, DR integration
 - Potential additional costs: implementation, added complexity, disputes

II. Modeling Approach

- Implemented study with SERVM, a probabilistic multi-area reliability and economic modeling tool, representing:
 - Demand in ERCOT and external regions
 - Generation with randomized outages
 - Demand response of several types with differing availability and emergency or economic triggers
 - Emergency procedures that ERCOT triggers in shortage conditions
- Monte Carlo simulation of 7,500 full annual (hourly-sequential) simulations at each reserve margin
- Primary outputs reported at each reserve margin include:
 - Reliability metrics (LOLE, LOLH, EUE)
 - Economic costs (production costs, DR curtailment costs, emergency intervention costs)
 - Market results (prices, energy margins)

Load Duration Curves Modeled

(Peak Hours, Before DR Gross-Up or Forecast Error)



II. Reliability-Based Reserve Margin Targets

- We estimated that a 14.1% reserve margin would be required to meet the traditional 1in-10 loss of load event (LOLE) standard;
 - At 11.5%, average LOLE is three times higher (with average MWh shed 25% higher)
- Results sensitive to:
 - Forward period at which supply decisions are locked in, and consequential load forecast error (LFE) that needs to be considered in analysis (removing LFE drops the reserve margin to 12.6%)
 - Likelihood of extreme 2011 weather recurring treated at 1% chance in base case (raising it to 1/15 or equal chance would increase the reserve margin to 16.1%)

Reserve	Total Annual Loss of Load			Average Outage Event			Reliability Index
Margin	LOLE	LOLH	EUE	Duration	Energy Lost	Depth	1/LOLE
(%)	(events/yr)	(hours/yr)	(MWh)	(hours)	(MWh)	(MW)	(1-in-X)
6.0%	2.51	7.99	16,402	3.18	6,531	2,053	0.4
7.9%	1.36	4.02	7,555	2.95	5,555	1,882	0.7
8.9%	0.91	2.62	4,750	2.88	5,214	1,811	1.1
9.8%	0.64	1.77	3,020	2.76	4,719	1,709	1.6
10.8%	0.44	1.19	1,921	2.68	4,323	1,614	2.2
11.8%	0.29	0.74	1,145	2.56	3,938	1,541	3.4
12.7%	0.18	0.46	664	2.49	3,592	1,445	5.4
13.7%	0.12	0.28	370	2.38	3,186	1,339	8.6
14.6%	0.08	0.18	229	2.26	2,939	1,300	12.8
15.6%	0.04	0.08	97	2.14	2,517	1,174	25.9
17.5%	0.01	0.03	29	2.00	2,142	1,069	72.9 5 brattle.com

II. Economically Optimal Reserve Margin



Total system costs include a large baseline of total system costs that do not change across reserve margins, including \$15.2 B/year in transmission and distribution, \$9.6 B/year in fixed costs for generators other than the marginal unit, and \$10B/year in production costs.

II. Energy-Only Market Equilibrium

- Risk neutral, equilibrium reserve margin determined by market forces, where supplier energy margins equal the gross Cost of New Entry (CONE)
- Current FRCOT market design results in 11.5% equilibrium reserve margin for base case (9-13% for sensitivity cases)
 - Equilibrium exceeds economic optimum because administrative scarcity prices exceed marginal costs in some cases
- Significantly greater uncertainty of actual outcomes



CC Energy Margins

II. Equilibrium Capacity Market Prices

- Capacity is valuable for reserve margin requirements above the 11.5% energy-only equilibrium
 - Equilibrium capacity price set by the market at Net CONE (gross CONE minus energy margins)
 - 1-in-10 reliability at 14.1% requires average capacity price of \$40/kW-yr (\$30-\$60/kW-y in sensitivity cases)
- Even at lower levels, a reserve margin mandate will prevent very low reserve margin outcomes, mitigate some boom-bust cycles, and make capacity more valuable than in equilibrium

Equilibrium Capacity Prices at different Reserve Margin Requirements



^{8 |} brattle.com

II. Volatility in Spot Prices and Energy Margins



At 11.5% the average annual energy price is 20% higher than at 14%; average of top 10% of annual prices (unhedged) is 50% higher. Median prices significantly below average.
9 | brattle.com

II. Supplier Net Revenues

- Total supplier net revenues must reach CONE (on a long-run average basis) to attract new entry
- At higher reserve margin mandates, the source of revenues shifts from energy to capacity market (capacity makes up 32% of net revenues at 1-in-10)
 - Volatility in supplier net revenues is reduced at higher reserve margins (but much of it can also be achieved through hedging)



10 | brattle.com

Supplier Net Revenues

II. Total Customer Costs

- ERCOT customer costs are minimized at the energy-only equilibrium and increase if higher reserve margin mandates are imposed
- A 14.1% reserve margin mandate (at 1-in-10) would increase customer costs by approximately \$400 mil/year or 1% in long-run equilibrium
- The near-term difference between energy-only and capacity markets is more substantial because energy prices are currently below equilibrium levels (excess capacity relative to energyonly equilibrium)



II. Summary of Results from ERCOT Report

		Energy-Only Market		Capacity Market at 1-in-10	
		Base Case	Sensitivity Cases	Base Case	Sensitivity Cases
Equilibrium Reserve Margin	(%)	11.5%	9.3%-12.9%	14.1%	12.6% - 16.1%
Realized Reliability					
Loss of Load Events	(events/yr)	0.33	0.27 - 0.85	0.10	0.10 - 0.10
Loss of Load Hours	(hours/yr)	0.86	0.68 - 2.37	0.23	0.22 - 0.23
Normalized EUE	(% of MWh)	0.0004%	0.0003% - 0.0013%	0.0001%	0.00008% - 0.0001%
Economics in Average Year					
Energy Price	(\$/MWh)	\$58	\$58 - \$60	\$48	\$46 - \$53
Capacity Price	(\$/kW-yr)	\$0	\$0 - \$0	\$39	\$30 - \$60
Supplier Net Revenue	(\$/kW-yr)	\$122	\$97 - \$122	\$122	\$97 - \$122
Average Customer Cost	(¢/kWh)	10.1¢	10.1¢ - 10.7¢	10.2¢	10.2¢ - 10.8¢
Total Customer Costs	(\$B/Yr)	\$35.7	\$35.7 - \$37.8	\$36.1	\$36.0 - \$38.3
Economics in Top 10% of Years					
Energy Price	(\$/MWh)	\$99	\$95 - \$102	\$65	\$58 - \$77
Capacity Price	(\$/kW-yr)	\$0	\$0 - \$0	\$76	\$30 - \$116
Supplier Net Revenue (Unhedged)	(\$/kW-yr)	\$362	\$173 - \$444	\$249	\$152 - \$302
Supplier Net Revenue (80% Hedged)	(\$/kW-yr)	\$244	\$119 - \$259	\$193	\$128 - \$289
Average Customer Cost (Unhedged)	(¢/kWh)	15.1¢	13.4¢ - 23.0¢	12.9¢	12.4¢ - 17.9¢
Average Customer Cost (80% Hedged)	(¢/kWh)	12.6¢	9.8¢ - 21.8¢	11.7¢	10.2¢ - 17.7¢
Total Customer Costs (Unhedged)	(\$B/Yr)	\$53.6	\$37.4 - \$81.5	\$45.7	\$43.9 - \$63.3
Total Customer Costs (80% Hedged)	(\$B/Yr)	\$44.7	\$34.6 - \$77.2	\$41.5	\$36.2 - \$62.9

III. FERC Study of Resource Adequacy

- Scope of September 2013 Study (released by FERC in Feb 2014):
 - Assessed economic/reliability implications of different resource adequacy standards.
 - Examine the widely-used one-day-in-ten-years (1-in-10) loss of load standard and compare it to alternative approaches to defining resource adequacy
 - Evaluate the implications of different resource adequacy standards from a customer cost, societal cost, risk mitigation, market structure, and market design perspective.
- Documented wide differences in application of 1-in-10 standard
 - 0.1 loss of load events (LOLE) per year interpretation is most widely used
 - 2.4 loss of load hours (LOLH) per year, economic reserve margins, and normalized expected unserved energy (EUE) also applied
- Even different applications of 0.1 LOLE standard and calculation of reserve margin have up to 5 percentage point impact on planning reserve margin
 - Different definition of "event" (e.g., load shed vs. operating reserve depletion)
 - Reserve margin based on name plate or de-rated capacity (e.g. for renewables)
 - Different treatment of intertie benefits, load growth uncertainty, etc.
- More explicit recognition of these wide difference would provide much-needed flexibility in market design for resource adequacy and flexibility needs

III. ERCOT vs. FERC Study Design

- The study design for FERC was based on a hypothetical but realistic, medium-sized "Study RTO"
- Unlike ERCOT, the Study RTO has significant transmission interconnections to three similarly-sized neighboring regions
 - Realistic resource mix based on scaled NYISO, MISO, PJM, and Southern Company data
 - Weather (hourly load and renewable generation) based on actual TVA, MISO, PJM, and SoCo data



III. Sensitivity to Intertie Capacity

- Overall, the results in FERC Study are very similar to ERCOT Report; however, difference in study scope provides additional insights on a number of topics
- Size of interconnection to neighboring system has large impact on both 1-in-10 (blue dots) and economically-optimal reserve margins (red dots)
- Strongly dependent reserve margins in neighboring systems



Total System Costs vs. Reserve Margin

III. Capacity Value of Demand Response

- Simulations of different levels of economic and (call-hour-limited) emergency DR show significant benefits of DR with economically optimal levels in 8%-14% range
 - Lower total costs, improved scarcity pricing, lower capacity prices
- Capacity value decreases with higher penetration for: (a) emergency DR with callhour limits and (b) economic DR with bid caps



III. Impact of Price Caps

- Simulations show that price caps substantially reduce the equilibrium reserve margins that can be achieved by energyonly market
- Energy market prices capped at levels below \$3,000/MWh significantly increase the "missing money" at any particular reserve margin
- Price caps shift necessary generator revenues from energy market to capacity market; reducing dispatch efficiencies and demand response during scarcity pricing periods

Energy Margins and Capacity Prices ("Missing Money") at Different Price Caps



III. Economic RM vs. Cost of New Entry

- Economicallyoptimal reserve margins decrease as the marginal cost of adding new resources increases
- Allows estimation of a capacity market "demand curve" that is not dependent on estimates for Net CONE



III. Demand-Curves for Capacity Markets

- Economicallydetermined demand curves for capacity are in the general range of RTOs' actual demand curve
- Very sensitive to market structure (such as interties with neighboring systems) and market design features (such as price caps)



Experience from the last decade strongly suggests that successful capacity markets require:

- 1. Well-defined resource adequacy objectives and drivers
- 2. Clear understanding why market design is deficient without capacity market (inefficient or not able to achieve resource adequacy targets)
- 3. Clearly-defined capacity products, consistent with needs
- 4. Well-defined obligations, auctions, verifications, and monitoring
- 5. Efficient spot markets for energy and ancillary services
- 6. Addressing locational reliability challenges
- 7. Participation from all resource types
- 8. Carefully-designed forward obligations
- 9. Staying power to reduce regulatory risk while improving designs and addressing deficiencies
- 10. Capitalizing and building on experience from other markets

IV. Some Caution About Capacity Markets

Market-based mechanisms, including capacity markets, offer unique efficiency and innovation advantages, reducing out-of market costs imposed on consumers

But don't prematurely add capacity markets...

- ...that explicitly or inadvertently:
 - discriminate between existing and new resources
 - exclude participation by demand-side and renewable resources
 - ignore locational constraints and transmission interties
- ...just to add revenues for certain resources or to address a perceived lack of long-term contracting
- ...while also providing out-of-market payments (including long-term contracts) to some resources <u>that oversupply the market</u> and distort both short- and long-term investment signals
- ...without understanding and addressing deficiencies in energy and ancillary service markets

V. Policy Implications

- The most appropriate market design (and reserve margin) depends on a regions' policy objectives and risk tolerance:
 - Energy-Only Market: likely the most appropriate design if economic efficiency is the primary policy objective, and the anticipated reserve margin, outage levels, and potential for periodic scarcity events is sustainable from a public policy perspective
 - Mandated Reserve Margins (e.g., implemented with Capacity Market): likely the most appropriate design if maintaining physical resource adequacy standards is the primary policy concern or policy makers wish to prevent potential low-reliability, high-cost events (thereby creating potential long-run benefits through risk-mitigation)
- Addressing this market design question appears to be less pressing while reserve margins are high, but doing so before reserve margins fall will:
 - Enable market participants to plan investment and contracting decisions under less regulatory uncertainty, and
 - If opting for a reserve margin mandate, provide sufficient time to carefully develop and implement the market design to avoid design flaws introduced through hasty implementation

Appendix A: Additional FERC Study Results

Uncertainties Considered in FERC Study

- Key uncertainties considered in FERC Study:
 - Forced/planned generation outages and intertie-transmission derates
 - Weather-related impacts on load and renewable generation (32 weather years)
 - Economic load-growth uncertainty over range of forward periods (1 to 10 years, 4-yr base)
- Administrative scarcity pricing, reserve depletion, DR- and emergency-generation

Study RTO Summer Peak Load under Different Weather Profiles





FERC Study Results

Planning Reserve Margins Required to Meet Different Physical Reliability Standards



FERC Study Results

Distribution of Loss of Load Hours at 12% Planning Reserve Margin Across Months (Left) and Across Simulation Years (Right)



FERC Study Results: Spot Energy Prices

Price Duration Curve at the Equilibrium Reserve Margin



Sensitivities: Physical and Economic RM

Reliability-Based and Economically-Based Reserve Margin Targets

(Across Base and Sensitivity Case Simulations)

Simulation]	Reliability-Base	Risk-Neutral, Cost-Minimizing		
-	0.1 LOLE	2.4 LOLH	0.001% Normalized EUE	Cost-of-Service Perspective	Societal Perspective
Base Case	15.2%	8.2%	9.6%	10.3%	7.9%
Lower Price Caps					
\$1,000 Price Cap Case	15.2%	8.2%	9.6%	8.7%	7.9%
\$3,000 Price Cap Case	15.2%	8.2%	9.6%	9.5%	7.9%
Smaller System Size					
40% Size Case	14.8%	<6%	7.5%	<6%	<6%
40% Size and Transmission	15.1%	6.9%	8.1%	<6%	<6%
Neighbor Assistance					
Long Neighbors Case	13.0%	<6%	7.0%	8.0%	<6%
50% Transmission Case	15.8%	9.8%	10.0%	12.3%	10.5%
Island Case	18.5%	16.5%	15.8%	16.5%	16.5%
Marginal CC Case	15.3%	8.3%	9.8%	10.1%	7.7%

Additional Sensitivities: Economic RM

Sensitivity of Economically Optimal Reserve Margin to Economic Study Assumptions (Risk Neutral, Cost-of-Service Perspective)

	Reserve Margin Range (% ICAP)	Base Case	Low/High Sensitivity
Base Case	10.30%	n/a	n/a
Emergency Event Costs			
Emergency Generation	10.2% - 10.5%	\$500/MWh	\$250 - \$1000/MWh
Emergency DR	9.9% - 10.9%	\$2000/MWh	\$1000 - \$3000/MWh
Emergency Hydro	10.2% - 10.5%	\$3,000/MWh	\$1,500 - \$6,000/MWh
Voltage Reduction	10.2% - 10.4%	\$7,000/MWh	\$3,500 - \$14,000/MWh
VOLL	10.0% - 11.6%	\$7,500/MWh	\$3,750 - \$15,000/MWh
All Emergency Event Costs	9.2% - 12.1%	Base	50% or 200% Base
Other Assumptions			
Load Forecast Error	9.4% - 11.0%	4 Years Forward	2 Years - 6 Years
CONE	9.5% - 11.3%	\$120/kW-y	\$100 - \$140/kW-y
Transmission Ownership	8.3% - 12.3%	50/50 Ownership	Importer/Exporter Owns

Appendix B: Characteristics of Successful Capacity Markets (additional detail)

- **1.** Well-defined resource adequacy objectives and drivers
 - Meet seasonal/annual peak loads or ramping/flexibility constraints?
 - Drivers of the identified needs?
 - System-wide or location-specific due to transmission constraints?
 - Near-term vs. multi-year forward deficiencies? Uncertainty of projected multi-year forward needs?
 - Ability of all demand- and supply-side resources , including interties, to meet the identified need?

- 2. Clear understanding why the market design is inefficient or will not achieve resource adequacy targets without a capacity market
 - Energy market designs that lead to price suppression?
 - Low price caps and inadequate scarcity pricing?
 - Poor integration of demand-response resources?
 - Substantial locational differences not reflected in market prices?
 - Operational actions that depress clearing prices?
 - Challenging investment risks (e.g., in hydro-dominated markets)?
 - Distortions created by out-of-market payments for some resources that lead to over-supply or high costs?
 - Incomplete or poorly-designed ancillary service markets?
 - Missing ramping products?
 - Not co-optimized with energy market?
 - Operational actions that depress clearing prices?
 - Most Likely: Resource adequacy preferences higher than what even fully-efficient energy and ancillary service markets would provide

- **3.** Clearly-defined capacity products, consistent with needs
 - Annual and seasonal capability
 - Near-term or multi-year forward obligations
 - Peak load carrying vs. ramping capability
 - Effective load carrying capability and outage rates of different resource types (including renewables, demand-response, and interties)
 - Integration with energy and ancillary service markets
- 4. Well-defined obligations, auctions, verifications, monitoring, and penalties
 - Ensure quality of resources and compliance without creating inadvertent bias against certain resources (e.g., demand-response, intermittent resources, imports)

5. Efficient spot markets for energy and ancillary services

- Capacity markets can "patch-up" deficiencies in energy and ancillary service markets from a resource adequacy perspective
- Less efficient investment signals (e.g., resource types, supply-vs. demand-side resources, locations) if deficiencies in energy and ancillary service are not addressed

6. Addressing locational reliability challenges

- Resource adequacy won't be addressed efficiently if reliability concerns are locational but capacity markets aren't
- Requires locational resource adequacy targets and market design
- Requires understanding of how transmission (including interties between power markets) affect resource adequacy

7. Participation from all resource types

- Existing and new generating plants
- Conventional, renewable/intermittent, and distributed generation
- Load (demand response)
- Interties (actively committed imports vs. resource adequacy value of uncommitted interties)

8. Carefully-designed forward obligations

- Efficiency of near-term obligations (avoid forecasting uncertainty, adjust to changes in market conditions, reduced commitment risk)
- Benefits of multi-year forward obligations (competition between new and existing resources; forward visibility; financial certainty)
- Questionable need for forward commitments greater than 3-4 years
- Avoid capacity markets as substitute for long-term contracts

- 9. Staying power to reduce regulatory risk while improving designs
 - Staying power of market design reduces regulatory risk and improves investment climate
 - Requires careful balancing of staying power and the need to improve design elements and address deficiencies
 - Challenge due to strong financial interests of different stakeholders

10. Capitalizing and building on experience from other markets

- Regional difference are important but often overstated
- Avoid the "not invented here" syndrome
- Avoid "urban myths" (e.g., no new generation built in regions with capacity markets; insufficient to support merchant investments unless 5-10 year payments can be locked in)

Appendix C: Additional Reading, About the Authors and Brattle

Additional Reading

Newell, Spees, Pfeifenberger, Karkatsouli, Wintermantel, Carden. *Estimating the Economically Optimal Reserve Margin in ERCOT*, Report prepared for the PUCT, January 31, 2014.

Pfeifenberger. Market-based Approaches to Resource Adequacy, IESO Stakeholder Summit, Feb. 11, 2014.

Pfeifenberger, Spees. Characteristics of Successful Capacity Markets, APEx Conference, October 31, 2013.

Pfeifenberger, Spees, Carden and Wintermantel, *Resource Adequacy Requirements: Reliability and Economic Implications*, Report prepared for FERC, September 2013.

- Spees, Newell, Pfeifenberger. "Capacity Markets: Lessons Learned from the First Decade," *Economics of Energy & Environmental Policy*. Vol. 2, No. 2, September 2013.
- Spees, Pfeifenberger. "PJM's Energy and Capacity Markets: Outlook on Fundamentals," 12th Annual Power & Utility Conference, Goldman Sachs, August 8, 2013.
- Pfeifenberger, Spees. "Evaluation of Market Fundamentals and Challenges to Long-Term System Adequacy in Alberta's Electricity Market," March 2013 (Update) and April 2011 (Original Study).
- Pfeifenberger. "Structural Challenges with California's Current Forward Procurement Construct." CPUC and CAISO Long-Term Resource Adequacy Summit. San Francisco, February 26, 2013
- Newell, Spees. "Get Ready for Much Spikier Energy Prices: The Under-Appreciated Market Impacts of Displacing Generation with Demand Response." February 2013.
- Pfeifenberger, Spees, Newell. "Resource Adequacy in California: Options for Improving Efficiency and Effectiveness," October 2012.
- Newell, Spees, Pfeifenberger, Mudge, DeLucia, Carlton, "ERCOT Investment Incentives and Resource Adequacy," June 2012.

Additional Reading (cont'd)

- Pfeifenberger, Newell. "Trusting Capacity Markets: Does the Lack of Long-Term Pricing Undermine the Financing of New Power Plants?" *Public Utilities Fortnightly*. December 2011.
- Pfeifenberger, Newell, Spees, Hajos, Madjarov. "Second Performance Assessment of PJM's Reliability Pricing Model: Market Results 2007/08 through 2014/15." August 26, 2011.
- Spees, Newell, Carlton, Zhou, Pfeifenberger. "Cost of New Entry Estimates for Combustion Turbine and Combined-Cycle Plants in PJM." August 24, 2011.
- Carden, Pfeifenberger and Wintermantel. "The Economics of Resource Adequacy Planning: Why Reserve Margins Are Not Just About Keeping the Lights On." NRRI Report 11-09. April 2011.
- Newell, Spees, Hajos. "The Midwest ISO's Resource Adequacy Construct: An Evaluation of Market Design Elements." *The Brattle Group*, January 19, 2010.
- Newell, Bhattacharyya, Madjarov. "Cost-Benefit Analysis of Replacing the NYISO's Existing ICAP Market with a Forward Capacity Market." June 15, 2009.
- LaPlante, Chao, Newell, Celebi, Hajos. "Internal Market Monitoring Unit Review of the Forward Capacity Market Auction Results and Design Elements." ISO New England and *The Brattle Group*. June 5, 2009.
- Pfeifenberger, Spees. "Best Practices in Resource Adequacy." PJM Long Term Capacity Issues Symposium. January 27, 2010.
- Pfeifenberger, Spees, Schumacher. "A Comparison of PJM's RPM with Alternative Energy and Capacity Market Designs." September 2009.
- Pfeifenberger, Newell, Earle, Hajos, Geronimo. "Review of PJM's Reliability Pricing Model (RPM)." June 30, 2008.
- Reitzes, Pfeifenberger, Fox-Penner, Basheda, Garcia, Newell, Schumacher. "Review of PJM's Market Power Mitigation Practices in Comparison to Other Organized Electricity Markets," September 2007.

Author Contact Information



JOHANNES P. PFEIFENBERGER

Principal | Cambridge, MA <u>Hannes.Pfeifenberger@brattle.com</u> +1.617.234.5624



SAMUEL A. NEWELL Principal | Cambridge, MA Samuel.Newell@brattle.com +1.617.234.5725



KATHLEEN SPEES

Senior Associate | Cambridge, MA Kathleen.Spees@brattle.com +1.617.234.5783



About the Brattle Group

The Brattle Group provides consulting and expert testimony in economics, finance, and regulation to corporations, law firms, and governmental agencies worldwide.

We combine in-depth industry experience and rigorous analyses to help clients answer complex economic and financial questions in litigation and regulation, develop strategies for changing markets, and make critical business decisions.

Our services to the electric power industry include:

- Climate Change Policy and Planning
- Cost of Capital
- Demand Forecasting Methodology
- Demand Response and Energy Efficiency
- Electricity Market Modeling
- Energy Asset Valuation
- Energy Contract Litigation
- Environmental Compliance
- Fuel and Power Procurement
- Incentive Regulation

- Rate Design and Cost Allocation
- Regulatory Strategy and Litigation Support
- Renewables
- Resource Planning
- Retail Access and Restructuring
- Risk Management
- Market-Based Rates
- Market Design and Competitive Analysis
- Mergers and Acquisitions
- Transmission

Offices

NORTH AMERICA



Cambridge

New York



San Francisco



Washington, DC

EUROPE



London

Madrid

Rome

